

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236539
Address: 3735 SW CLAYTON PL, LEES SUMMIT, MO 640823737 SW CLAYTON PL, LEES SUMMIT, MO
640823739 SW CLAYTON PL, LEES SUMMIT, MO 640823733 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Failed	Monday, April 15, 2024

Corrective Action Required:

1	Miscellaneous Correction	3733 SW Clayton. Rated assembly Ok 3735 garage south wall at the top has plywood attached to it Entry north wall has metal bent and exposes a gap Fire blocking nominal Luis missing along north wall on main floor Rafter bracing repair in upstairs bedroom 1 needs to be replaced by fire protection plywood 3737 entry rated wall has plywood attached to the top Electrical service cable along north wall needs to be fire caulked Gap at the south rated wall along the roof line Gap above ceiling in bedroom 1 to the north/west corner 3739 Roof decking has a larger than 1/4 inch gap on the east side
---	-----------------------------	--

Comments:

