

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20226036  
Address: 201 SE M 291 HWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                     | Inspector:   | Outcome: | Date:                   |
|---------------------------------|--------------|----------|-------------------------|
| <b>Miscellaneous Inspection</b> | Alex Fischer | Failed   | Tuesday, April 16, 2024 |

Informational:  
1      Misc      -Performed miscellaneous inspection on 4/10/24 determined per Joe Frogge that incorrect materials were used as separation wall between sprinkler riser room and retail space. Drawings revised, submitted and approved. Waiting on replacement wall to be built per new specs.

**Comments:**