

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20230682
Address: 1501 SW ARBORWALK BLVD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	Patrick Schonfeldt	Passed	Tuesday, April 16, 2024

Informational:

1	Misc	4-9-24 PS Observed vac test of sanitary manholes, partial inspection
		SS 1-1 Passed
		SS 1-2 Passed
		SS 1-5 Passed
		4-12-24 PS Observed vac test of sanitary manhole
		SS1-3 Passed
		4-16-24 PS Observed vac test of sanitary manhole
		SS1-4 Passed
		Sanitary testing complete

Comments: