

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20240499

Address: 2237 NE TOWN CENTRE BLVD, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Khanh Nguyen	Failed	Tuesday, April 16, 2024

Corrective Action Required:

1	Misc	In-wall for rm 110-121 only: -Fire block combustible wall space at top and vertically every ten ft; fb wall top plates penetrations -Protect refrigerant lines
---	------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------

Comments: