

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241108
Address: 2520 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sewer Service Inspection - R	Khanh Nguyen	Partial	Tuesday, April 16, 2024

Corrective Action Required:

1 Misc

Sewer connection to pit -OK

Remove extra check valve and reconnect to PE sewer stub. Take picture when done

Comments: