

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20226232  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	Robb Popp	Partial	Wednesday, April 17, 2024

Corrective Action Required:

1	FIRST FLOOR	**OK to top out one side for mechanical as necessary **OK to top out both sides at corridor 1E-100H and 1E-100G for MEPs  In-wall inspected: rm 1E-103-109; 1E-111-117; 1E-122; 1E-124-138; 1E-146-148; corr 1E-100A/C/G. Protected PVC within 1.25" of track surface
---	-------------	---

Informational:

2	SECOND FLOOR	**OK to top out corridors for MEPs as necessary  *EXISTING SIDE; -2E419 electrical room ok to 1 side
---	--------------	---

Corrective Action Required:

3	THIRD FLOOR	
---	-------------	--

**Comments:**