

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236294

Address: 2118 SW HOLDBROOKS DR, LEES SUMMIT, MO 64082
2116 SW HOLDBROOKS DR, LEES SUMMIT,
MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Partial	Wednesday, April 17, 2024

Informational:

1	Miscellaneous Correction	Full erosion control is in place and must be maintained until CofO
---	--------------------------	--

Corrective Action Required:

2	Miscellaneous Correction	Silt fence at street is damaged or missing and needs to be repaired or replaced. Full erosion control must be maintained until CofO
---	--------------------------	---

Corrective Action Required:

3	DCM3 ESC REQUIRED 2 DAY	4-17-24 Dustin A. EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS.
---	----------------------------	--

Comments: