

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240887
Address: 1840 SW SAGE CANYON RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Thursday, April 18, 2024

Corrective Action Required:

2	Miscellaneous Correction	1840 SW Sage Canyon. All rough (2) Have engineer address where the cricket above the garage intersects and supports two roof loads without vertical support (engineers letter has not been uploaded as of the time of re inspection 9:05 am)
---	--------------------------	---

Comments: