CITY OF LEE'S SUMMIT **Development Services Department** 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222242

530 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064 Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Sanitary Sewer Construction Nick Scott Passed Thursday, April 18,

Inspection 2024

Corrective Action Required:

12-12-22 Sanitary line that goes over the storm needs to be encased in 1 Miscellaneous Correction

concrete. the sewer line still needs to be tested after the 30 day waiting

period of completion.

No TCO will be issued until the sewer is approved by water utilities 4-18-24 NS Site visited and the sewer. It appears it has passed from water

utilities.

Comments: