

DEVELOPMENT SERVICES

Residential Plan Review

April 18, 2024

CLAYTON PROPERTIES GROUP, INC 120 SE 30TH ST LEES SUMMIT, MO 64082 (816) 246-6700

Permit No: PRRES20241821

Plan Name:

Project Address: 3220 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

Parcel Number: 69620110600000000

Location: HAWTHORN RIDGE 2ND PLAT LOTS 101-159 INCL---LOT 149

Type of Work: NEW SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: NEW HOUSE. UNFINISHED BASEMENT. UNCOVERED DECK. ROOF TRUSSES.

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and/or additional information to the application through the online portal. Please contact the Development Services Department with any questions you may have.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Andrea Sessler Rejected

1. A as-graded plot plan per Section 7-160, Code of Ordinances, is required prior to occupancy.

Residential Plan Review Reviewed By: Andrea Sessler Rejected

1. Identify emergency escape openings from bedrooms and basement(s). (IRC Section R310 as amended per Ordinance)

PLEASE LABEL PRIMARY BEDROOM EGRESS WINDOW.

Planning Review RES Reviewed By: Hector Soto Jr. Pending

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

Residential Area:	
Residential, garage	455

Residential, Living Area (Not Finished Basement) Residential, Un-Finished basements		2066 743		
Roofing Material		Number of Bathrooms	2	
Number of Bedrooms	4	Number of Stories	2	
Number of Living Units	1	Total Living Area	2066	