



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110759, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Tuesday, August 30, 2011
Partial Correction 1 MISC		FRAMING & ABOVE-CEILING SYSTEMS @ GWB CEILINGS & SOFFITS: SOFFITS @ 00; 01; 02; 05; 23; 77;	
Rated Assembly Inspection	John Borns	Partial	Tuesday, August 30, 2011
Partial Correction 1 MISC		OK TO TAPE, MUD, AND FIRE-SEAL FOLLOWING RATED WALLS: 02; 04; 06; 08; 09; 10; 13; 15; 17; 19; 21; 27; 29; 30; 69 PER RFI #1; 82 S END WALL; 83; 84; 85	

Comments: