## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20233908

Address: 2731 SW HEARTLAND RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Failed Friday, April 19, 2024

Residential

Corrective Action Required:

1 Miscellaneous

Correction -final grade and sod

-splash blocks and sump pump discharge to extend 36" from foundation

-address pending sidewalk inspection

-provide as graded plot plan

-stairs to loft area to be no greater than 3/8" difference.

**Comments:**