

CODE MODIFICATION REQUEST

(COMMERCIAL)

BUILDING/STRUCTURE NAME: Image Studios	
PREMISE ADDRESS: 840-D NW Blue Parkway, Lee's Summit, MO 64086	
PERMIT NUMBER (if applicable): PRCOM20241344	
OWNER'S NAME: Lily Mantych	
TO: Director of Development Services	
In accordance with the Lee's Summit Building Code, I wish to apply for a modification to one or more provisions of the code as I feel that the spirit and intent of the Lee's Summit Building Code are observed the public health, welfare and safety are assured. The following articulates my request for your review and action. (NOTE: ATTACH ANY ADDITIONAL INFORMATION NECESSARY) Please see the attached document.	
SUBMITTED BY:	
	() OWNER (X), OWNER'S AGENT
ADDRESS: 8813 Penrose Lane, Suite 400	Tel.# 913-649-8181
CITY, STATE, ZIP: Lenexa, KS 66215	SIGNATURE:
TRACY DEISTER – MANAGER OF CODES ADMINISTRATION: () APPROVAL () DENIAL	
SIGNATURE:	DATE:
AIMEE NASSIF – DEPUTY DIRECTOR OF DEVELOPMENT SERVICES: () APPROVED () DENIED	
SIGNATURE:	DATE:
COMMENTS:	

A COPY MUST BE ATTACHED TO THE APPROVED PLANS ON THE JOB SITE

9/18/2023 N:\CODES ADMIN\Forms 2019

April 18, 2024

VIA ONLINE PORTAL

Joe Frogge Building Plan Reviewer Lee's Summit Missouri Development Services 220 SE Green Street, Lee's Summit, MO 64063

IMAGE STUDIOS 840 NW BLUE PKWY, UNIT D, LEES SUMMIT, MO 64086 PERMIT NUMBER: PRCOM20241344

Joe Frogge,

Klover Architects, Inc. would like to formally request an exception/modification to the International Plumbing Code section 405.3.2, stating the required lavatory shall be located in the same room as the required water closet. The intent of code allows for sinks outside of toilet partitions in typical restroom layout/room. By having individual closet rooms that exit into one main area with lavatories still meets the intended purpose.

Thank you for your time in this process.

Sincerely,

Henry C. Klover President

CC: Lily Mantych Klover #:23060.003