

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20241065
Address: 3728 SW KNOXVILLE CT, LEES SUMMIT, MO 640823730 SW KNOXVILLE CT,
LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Kyle Beard	Failed - Stop Work	Monday, April 22, 2024

Corrective Action Required

1 Miscellaneous Correction Underslab plumbing

Underslab plumbing will not pass until all wood from forms which includes stakes are removed from contact of the ground.
R317.1.2 ground contact

Corrective Action Required

2 Miscellaneous Correction Underslab plumbing

- Underslab plumbing will not pass until all wood from forms which includes stakes are removed from contact of the ground.
R317.1.2 ground contact

- Footing inspection has not passed
- gravel needs to be installed between the street and foundation

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER is issued on this property until all items are
addressed and passed

Comments: