

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20222783  
Address: 1231 NW MAIN ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	Robb Popp	Partial	Monday, April 22, 2024

Informational:  
1 Misc -interior column pads approved

**\*\*Perimeter footings:**  
-Line Z complete  
-Line 5 complete  
-Line A from 5-3

**\*\*Ufer located at line A near line 3 pump room**

**Comments:**