

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234906  
Address: 2307 SW SERENA PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Not Ready	Tuesday, April 23, 2024

Informational:

1	Misc	Garage portal a covered back patio. Okay to cover
---	------	---

Corrective Action Required:

2	Misc	Inspection denied no fire blocking done throughout house No further inspections until erosion control is in compliance.
---	------	--

**Comments:**