

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233582
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Sediment Control (ESC) Inspection	Patrick Schonfeldt	Partial	Tuesday, April 23, 2024

Corrective Action Required:

1	Misc	4-23-24 PS Provide erosion control, re establish silt fence along arborridge drive where silt fence was removed for new storm ilte at corner of 150 highway. Provide erosion control at slop in same area to prevent erosion from soil pile at top of slope. Maintain gravel filter at construction entrance. Gravel embedded in soil allowing for vehicles to bring mud onto arborridge drive during rain events
---	------	--

Comments: