

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20236557
Address: 3723 SW CLAYTON PL, LEES SUMMIT, MO 640823725 SW CLAYTON PL, LEES SUMMIT, MO
640823727 SW CLAYTON PL, LEES SUMMIT, MO 640823721 SW CLAYTON PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Failed	Tuesday, April 23, 2024

Corrective Action Required:

1	Miscellaneous Correction	3727 Passed
---	-----------------------------	----------------

3725

- Fire blocking is missing in top plate at garage north wall
- Fire block top plate in entry at electrical wires
- Vertical fire block every 10 feet at stairwell to North West bedroom
- Remove wood at the ridge on North side
- Vertically fire block N/E bedroom's north wall every 10 feet
- This is a partial electrical inspection only
- Other units will be scheduled at a later date

Comments: