

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #:PRPWRW20242003, Public Works Right of Way Permit
Address: 3208 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Site Visit Inspection	Matt Munger	Partial	Wednesday, April 24, 2024

Corrective Action Required

1 Misc

Site Visit - Workers are actively working. I spoke with the foreman (Alex?) on the job and asked what depths they would be boring under the road, he stated 3ft. I informed him 3ft is our minimum depth for the road crossings. They have a pit fenced off and he stated they are going to try and use the existing sod to restore the grass. Monitoring.

Comments: