



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20113619, Building Permit - Commercial  
Address: 880 NW BLUE PKWY, Unit:D, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	John Borns	Partial	Wednesday, August 31, 2011

Corrective Action Required

1	MISC	EXPOSED PIPING TO BE PAINTED PRIOR TO FINAL INSPECTION
---	------	--

<b>Gas Service Inspection - Commercial</b>	John Borns	Not Ready	Wednesday, August 31, 2011
--	------------	-----------	----------------------------

Corrective Action Required

1	MISC	ADDRESS IDENTIFICATION OF GAS SERVICE ENTRY: WHERE TWO OR MORE SERVICES ARE GROUPED HANG ADDRESS-STAMPED MEDALLIONS ON LOAD SIDE PIPES
---	------	--

Corrective Action Required

2	MISC	LSCO 7-608: GAS PIPING PRESSURE TEST BELOW LEE'S SUMMIT 10 PSI REQUIRED MINIMUM
---	------	---

**Comments:**