

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241111  
Address: 2086 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection - R</b>	Dustin Agcopra	Partial	Wednesday, April 24, 2024

Corrective Action Required:

1	Misc	4-24-24 Dustin A, Tap hole spoils on the rd, Will need to be cleaned up before end of day. Water line is to shallow at the curb will need to be deeper.
		4-24-24 Dustin A, Contractor fixed the depth of copper service, Copper tail piece is to short, Gave partial so the spoils can be removed from road. Tail piece needs to be extended and meter height was to shallow

Comments: