CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE PROSECUTED

Permit #: PRRES20240545

Address: 3713 SW CLAYTON PL, LEES SUMMIT, MO 640823715 SW CLAYTON PL, LEES

SUMMIT, MO 640823717 SW CLAYTON PL, LEES SUMMIT, MO 640823711 SW

CLAYTON PL, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Erosion Control Dustin Agcopra Failed - Stop Work Thursday, April 25, 2024

Corrective Action Required

1 Misc -NW Corner, silt fence needs repair

EROSION CONTROL MUST BE MAINTAINED UNTIL C of O

Corrective Action Required

2 DCM1 ESC REQUIRED NO 4-25-24 Dustin A,

FURTHER INSP EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL

BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN

COMPLIANCE.

Comments: