

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20240759
Address: 3517 SE CORBIN DR, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Dustin Agcopra	Failed - Stop Work	Thursday, April 25, 2024

Corrective Action Required

1	Miscellaneous Correction	Front yard silt fence at the street is torn down and damaged, replace or repair. Full erosion control must be maintained until CofO
---	--------------------------	---

Corrective Action Required

2	DCM1 ESC REQUIRED NO FURTHER INSP	4-25-24 Dustin A, EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.
---	-----------------------------------	--

Comments: