

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240344
Address: 2779 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Thursday, April 25, 2024

Corrective Action Required:

1 Misc

Fb = Fire block

- Fb top of chase pantry/ garage
- Fb top of chase master toilet/ living room
- Fb floor at master bedroom window
- Provide attic access second floor

Comments: