

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20240545  
Address: 3713 SW CLAYTON PL, LEES SUMMIT, MO 640823715 SW CLAYTON PL, LEES SUMMIT, MO  
640823717 SW CLAYTON PL, LEES SUMMIT, MO 640823711 SW CLAYTON PL, LEES  
SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control</b>	Dustin Agcopra	Passed	Thursday, April 25, 2024

Corrective Action Required:  
1 Misc -NW Corner, silt fence needs repair

EROSION CONTROL MUST BE MAINTAINED UNTIL C of O

Corrective Action Required:  
2 DCM1 ESC 4-25-24 Dustin A,  
REQUIRED NO EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE  
FURTHER INSP PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE.

**Comments:**