

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20235728

Address: 3726 SW MARYVILLE PL, LEES SUMMIT, MO 640823728 SW MARYVILLE PL, LEES SUMMIT, MO
640823730 SW MARYVILLE PL, LEES SUMMIT, MO 640823722 SW MARYVILLE PL, LEES
SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Dustin Agcopra	Failed	Friday, April 26, 2024

Corrective Action Required:

1	Misc	3-12-24 Dustin A, Talked with contractor on some issues needing fixed. Moved to 3-13 3-13-24 Dustin A, SW is formed and compacted to city specs. Approved to pour 3-28-24 Dustin A, Sw has partially picture framed panels and picture framed panels which are not permitted 4-26-24 Dustin A, SW passed
---	------	--

Comments: