CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241425

Address: 1801 SW MERRYMAN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Final Building Inspection - Kyle Beard Failed Friday, April 26, 2024

Residential

Corrective Action Required:

1 Miscellaneous -Label raceway with power source decal

Correction -Contact label missing on electrical meter base

Comments: