





Hydraulic Calculations by HydraCALC

ADVANTAGE FIRE PROTECTION
404B N.W. 11TH ST
BLUE SPRINGS, MO 64015
816-224-3400

Job Name : LOT 1
Drawing : NE MAGUIRE BLVD.
Location : LEE'S SUMMIT, MO
Remote Area : AREA #1
Contract : J-2351
Data File : 4-19-2024 reliable Extended coverage AREA#1.WXF

Hydraulic Design Information Sheet

Name - LOT 1 Date - 4-4-2024
Location - LEE'S SUMMIT, MO
Building - NE MAGUIRE BLVD.
Contractor -
Calculated By - DANIAL LOGSTON
Construction: () Combustible (X) Non-Combustible
Occupancy - WAREHOUSE

System No. - AREA #1
Contract No. - J-2351
Drawing No. - 2 OF 4
Ceiling Height - 28-0

S (X) NFPA 13 () Lt. Haz. Ord.Haz.Gp. () 1 (X) 2 () 3 () Ex.Haz.
Y () NFPA 231 () NFPA 231C () Figure Curve
S Other
T Specific Ruling Made By Date

M Area of Sprinkler Operation - 1894.226 System Type Sprinkler/Nozzle
Density - .2 (X) Wet Make RELIABLE
D Area Per Sprinkler - 400 () Dry Model R6553
E Elevation at Highest Outlet - 126.958 () Deluge Size 3/4"
S Hose Allowance - Inside - () Preaction K-Factor 14
I Rack Sprinkler Allowance - () Other Temp.Rat.212
G Hose Allowance - Outside - 250
N

Note

Calculation Flow Required - 745.764 Press Required - 95.124
Summary C-Factor Used: 120 Overhead 140 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 8-10-2023 Cap. -
T Time of Test - 10:20AM Rated Cap.-
E Static Press - 105 @ Press -
R Residual Press - 76 Elev. -
S Flow - 2300 Well
U Elevation - 95 Proof Flow

Location -

Source of Information - LS WATER DEPT

C Commodity Class Location
O Storage Ht. Area Aisle W.
M Storage Method: Solid Piled % Palletized % Rack
M
S () Single Row () Conven. Pallet () Auto. Storage () Encap.
R () Double Row () Slave Pallet () Solid Shelf () Non
T () Mult. Row () Open Shelf
O
C

R K Flue Spacing Clearance:Storage to Ceiling
A Longitudinal Transverse

Horizontal Barriers Provided:


Water Supply Curve

ADVANTAGE FIRE PROTECTION
LOT 1

Page 2
Date 4-4-2024

City Water Supply:
C1 - Static Pressure : 105
C2 - Residual Pressure: 76
C2 - Residual Flow : 2300

Demand:
D1 - Elevation : 13.751
D2 - System Flow : 495.764
D2 - System Pressure : 95.124
Hose (Demand) : 250
D3 - System Demand : 745.764
Safety Margin : 6.266



Fittings Used Summary

ADVANTAGE FIRE PROTECTION
LOT 1

Page 3
Date 4-4-2024

Fitting Legend																					
Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
B	NFPA 13 Butterfly Valve	0	0	0	0	0	6	7	10	0	12	9	10	12	19	21	0	0	0	0	0
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65					
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90' Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	4.5	5.1	0	0	0	0	0
X	90'Tee-BranchFirelock002	0	0	0	0	0	8.5	10.8	13	0	16	21	25	33	9.3	11	0	0	0	0	0
Zce	Colt C300 Vert Butt	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Flow Summary - NFPA

ADVANTAGE FIRE PROTECTION
LOT 1

Page 4
Date 4-4-2024

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
TEST	105.0	76	2300.0	101.39	745.76	95.124

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>	
1	126.75	14	32.7	80.06	0.2	400
2	125.917	14	33.99	81.62	0.2	400
3	125.084	14	37.75	86.02	0.2	400
7	124.542		47.79			
4	126.75	14	32.92	80.33	0.2	400
5	126.75	14	33.85	81.46	0.2	400
6	125.084	14	37.98	86.28	0.2	400
14	124.542		48.05			
A1	122.667		54.4			
A2	122.667		54.67			
A4	122.667		75.03			
TOR1	122.667		78.2			
BOR1	101.833		87.72			
BOR2	101.833		87.74			
UNG	101.0		88.53			
UNG1	95.0		94.9			
TEST	95.0		95.12	250.0		

Final Calculations : Hazen-Williams

ADVANTAGE FIRE PROTECTION
LOT 1

Page 5
Date 4-4-2024

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
1 to 2	126.750 125.917	14.00	80.06 80.06	2 2.157			18.333 18.333	120 0.0506	32.700 0.361 0.927			
2 to 3	125.917 125.084	14.00	81.62 161.68	2 2.157			18.333 18.333	120 0.1857	33.988 0.361 3.404	Vel = 7.03		
3 to 7	125.084 124.542	14.00	86.02 247.7	2 2.157	T	12.307	11.667 12.307 23.974	120 0.4089	37.753 0.235 9.802			
7 to A1	124.542 122.667		0.0 247.7	2 2.157	T	12.307	1.875 12.307 14.182	120 0.4088	47.790 0.812 5.798			
A1			0.0 247.70						54.400		K Factor = 33.58	
4 to 5	126.750 126.750	14.00	80.33 80.33	2 2.157			18.333 18.333	120 0.0509	32.920 0.0 0.933			
5 to 6	126.750 125.084	14.00	81.45 161.78	2 2.157			18.333 18.333	120 0.1859	33.853 0.722 3.408			
6 to 14	125.084 124.542	14.00	86.29 248.07	2 2.157	T	12.307	11.667 12.307 23.974	120 0.4099	37.983 0.235 9.828			
14 to A2	124.542 122.667		0.0 248.07	2 2.157	T	12.307	1.875 12.307 14.182	120 0.4100	48.046 0.812 5.815			
A2			0.0 248.07						54.673		K Factor = 33.55	
A1 to A2	122.667 122.667		247.70 247.7	4 4.26			18.333 18.333	120 0.0149	54.400 0.0 0.273			
A2 to A4	122.667 122.667		248.06 495.76	4 4.26	T	26.334	352.958 26.334 379.292	120 0.0537	54.673 0.0 20.354			
A4 to TOR1	122.667 122.667		0.0 495.76	4 4.26	V	8.954	50.167 8.954 59.121	120 0.0537	75.027 0.0 3.173			
TOR1 to BOR1	122.667 101.833		0.0 495.76	6 6.357	B X	12.573 31.433	20.833 44.006 64.839	120 0.0076	78.200 9.023 0.495			
BOR1 to BOR2	101.833 101.833		0.0 495.76	6 6.357			2.500 2.500	120 0.0080	87.718 0.0 0.020			
BOR2 to UNG	101.833 101		0.0 495.76	6 6.357	S V	40.235 12.573	3.396 52.808 56.204	120 0.0076	87.738 0.361 0.429			
UNG to UNG1	101 95		0.0 495.76	6 6.16	Zce E G	0.0 20.084 4.304	79.000 67.425 146.425	140 0.0067	88.528 5.391 0.980			
										** Fixed Loss = 2.792		
										Vel = 5.34		

Final Calculations : Hazen-Williams

ADVANTAGE FIRE PROTECTION
LOT 1

Page 6
Date 4-4-2024

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Equiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
					T	43.037						
UNG1 to TEST	95 95		0.0 495.76	12 12.34	E G	42.195 9.377	937.000 51.572	140 0.0002	94.899 0.0 0.225		Vel = 1.33	
						250.00 745.76				95.124	Qa = 250.00 K Factor = 76.46	