

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20224595
Address: 2122 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Monday, April 29, 2024

Corrective Action Required:

1	Misc	-obtain lawn irrigation permit -address to be properly illuminated -outlets in garage to comply with E3901.9 (dedicated outlet per vehicle bay) -all non GFCI outlets in unfinished areas to be single receptacle outlets and labeled -afci protection as required by E3902.16 -lockouts for any hard wired appliances breakers. -uncover all smoke detectors and remove battery pull tab for inspection of smokes (smoke detectors to be interconnected)
---	------	---

Comments: