

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20234205

Address: 1441 SW WINTHROP TER, LEES SUMMIT, MO 640811443 SW WINTHROP TER, LEES SUMMIT, MO  
64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Bobby Richest	Passed	Monday, April 29, 2024

Corrective Action Required:

1	Misc	4-16-24 BR Driveway is framed and aggregate is placed but needs to be compacted before concrete is poured.
		4-22-23 BR Driveway is compacted and ready for concrete.
		4-29-24 BR Driveway is constructed to LS specifications.

**Comments:**