

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20231105  
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Monday, April 29, 2024

Informational:

1	Misc	-Building 1, Segment A, 1st through 4th Floor for first layer of rated assembly behind all tubs approved
---	------	----------------------------------------------------------------------------------------------------------

Corrective Action Required:

2	FIRST FLOOR	Building A: Decks approved
---	-------------	-------------------------------

Corrective Action Required:

3	SECOND FLOOR	Building A: Decks approved
---	--------------	-------------------------------

Corrective Action Required:

4	THIRD FLOOR	*BUILDING A: -Decks approved except as noted: 301- Nail H2.5's, install haner at end joist at deck
---	-------------	----------------------------------------------------------------------------------------------------------

\*\*\*\*\*UNITS AND CORRIDOR ONLY

-THROUGHOUT

-Address over spanned dryer ducts per manufacturer's listing

-Fire caulk all dryer ducts through exterior walls-

-Install kickers at trusses per structural plans S3.12-INSTALL AT MAX 48" OC

301-strap over bored top plate

304-Seal draft stop, over bored stud

305-strap over bored top plate  
306-3 nm cables in single top plate penetration  
307-strap top plate at closet lapped less than 48"  
308-3 nm cables in single top plate penetration, missing stud at back room,  
address hole in truss top chord

Corrective Action Required:

5

FOURTH FLOOR

\*BUILDING A:

-Approved

**Comments:**