

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20230406  
Address: 1204 NE WOODS CHAPEL RD, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Aggregate Base</b>	Nick Scott	Partial	Tuesday, April 30, 2024

Corrective Action Required:

1	Misc	1-4-24 NS Site visited and it appears some of the base has failed in part of the road and will need to be redone. 4-30-24 NS Site visited and construction crew has dug up all parts of road that have failed and will put asphalt back.
---	------	---

**Comments:**