

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20224595  
Address: 2122 SW RED BARN LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Tuesday, April 30, 2024

Corrective Action Required:

1 Misc

- outlets in garage to comply with E3901.9 (dedicated outlet per vehicle bay)
- all non GFCI outlets in unfinished areas to be single receptacle outlets and labeled
- afci protection as required by E3902.16
- lockouts for any hard wired appliances breakers.

**Comments:**