



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110759, Building Permit - Commercial
Address: 100 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Thursday, September 01, 2011
Partial Correction 1 MISC		FRAMING & ABOVE-CEILING SYSTEMS @ GWB CEILINGS & SOFFITS: SOFFITS @ 00; 01; 02; 05; 23; 77;	
Partial Correction 2 MISC		CEILING FRAMING & ABOVE-CEILING SYSTEMS AT NORTH ENTRANCE CANOPY OK TO COVER WHEN READY.	
Partial Correction 3 MISC		OK TO COVER WHEN READY EYEBROW SOFFIT/FASCIA FRAMING AT OUTSIDE WALL BORDERING PATIENT ROOMS AT CORRIDORS 18, 30, & 81	

Comments: