

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20223975
Address: 204 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Mandrel	Dustin Agcopra	Passed	Thursday, March 14, 2024

Informational:
1 Misc 3-13-24 Dustin A, Mandrel test has Passed
5-1-24 Dustin A, New mandrel test performed due to having to fix section of pipe . Passed.

Comments: