

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240573

Address: 3737 SW KNOXVILLE CT, LEES SUMMIT, MO 64082
3735 SW KNOXVILLE CT, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Thursday, May 02, 2024

Corrective Action Required:

1	Miscellaneous Correction	Garage 5/8 inch anchor bolts are not installed. Ok to cover exterior of garage with siding only. This inspection was for garage portal only
---	--------------------------	---

This is a partial inspection

Comments: