

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|--|------------|----------|----------------------|
| All Rough Inspection - Commercial | Robb Popp | Partial | Friday, May 03, 2024 |

Informational:

1 Misc

Corrective Action Required:

2 FIRST FLOOR

Building A:
Decks approved

Corrective Action Required:

3 SECOND FLOOR

Building A:
Decks approved
-Complete dwv above all showers
-Install stud shoes at over bored studs in corridor

Corrective Action Required:

4 THIRD FLOOR

*BUILDING A:
-Approved

Corrective Action Required:

5 FOURTH FLOOR

*BUILDING A:
-Approved

Corrective Action Required:

6 ELEVATOR 1

**ELEVATOR A:
-Ok for rock on inside of shaft all floors

Corrective Action Required:

7 STAIR TOWER 5

Stair tower D:
-Shear wall nailing pattern complete

Corrective Action Required:

8 STAIR TOWER 1 *Stair A
 -Approved

Comments: