

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20233582  
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Electrical Inspection - Commercial</b>	Mitchell Schwarz	Failed	Friday, May 03, 2024

Informational:	
1 Misc	INSECTED TRENCH AND CONDUIT SOUTH OF BUILDING
Corrective Action Required:	
2 Misc	All conduit underground to be minimum 18" and 24" under parking lot/drivable surfaces

**Comments:**