

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20240901
Address: 4412 SW GRINDSTONE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Not Ready	Monday, May 06, 2024

Corrective Action Required:

2	Miscellaneous Correction	4412 SW Grindstone. All rough -Fire block steel post in garage to basement -Install LIB according to plans Fire block hole in ceiling/ floor above garage -Stair stringers needs to be supported at least 1 1/2 inches on double 2x10 floor joist Okay to insulate only.
---	--------------------------	---

Comments: