

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242076

Address:

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Robb Popp	Failed	Monday, May 06, 2024

Corrective Action Required:

1	Misc	-Close open spaces in panel -Install bonding bushing and jumper for metallic raceway connected through knockout
---	------	--------------------------------------------------------------------------------------------------------------------

Comments: