

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242006
Address: 1220 NE PIEDMONT DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Alex Fischer	Failed	Monday, May 06, 2024

Corrective Action Required:

1	Misc	-Provide Bonding bushing and bond metal nipple to grounding buss bar -Bond metal service enclosure to grounded buss bar
---	------	--

Comments: