

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241195
Address: 4359 NE HIDEAWAY DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Alex Fischer	Failed	Tuesday, May 07, 2024

Corrective Action Required:

1	Misc	-Insufficient drain tile, should go the entire perimeter or diagonally from one corner all the way to opposite corner
---	------	---

Comments: