


HANGER Quantity SCHEDULE LUS24 0 LUS26 0 MO HUS26 15 Lot 184 Hawthorn Ridge ▲ HHUS26-2 0 1609 SW Arborway T
Lee's Summit
Chuck Haspels (785 ▲ HGUS26-2 0 ▲ HGUS28-3 0 LTHJA26 0 TJC37 0 TJC57 0 △ HTS20 0 Triangle denotes the left end of the Truss as it appears on the Engineered Drawings Job Name Customer Job Site / City,

Designer
4/23/2024

provided.



Unless otherwise specified by Engineer Of Record, Wheeler Lumber, LLC recommends an uplift connection at each bearing point per the following:

of Uplift Connector 0 - 495: (1) H2.5A 495 - 990: (2) H2.5A 990 - 1245: (1) HTS20

Installation per Simpson Strong-Tie guidelines.

For Reactions greater than 1245#, refer to EOR.

HIS LAYOUT IS THE SOLE SOURCE FOR FABRICATION OF TRUSSES AND VOIDS ALL PREVIOUS ARCHITECTURAL OR OTHER TRUSS LAYOUTS. REVIEW AND APPROVAL OF THIS LAYOUT MUST BE RECEIVED BEFORE ANY TRUSSES WILL BE BUILT. VERIFY ALL CONDITIONS TO INSURE AGAINST CHANGES THAT WILL RESULT IN EXTRA CHARGES TO YOU.

Wheeler Lumber 1959 Old Hwy 50 NE Waverly, KS 66871

Wall Heights 9-01-02 U.N.O. 10-01-02

> **EVERSTEAD** SHOP DRAWING / SUBMITTAL

REVIEW

SUBMITTAL WAS REVIEWED FOR DESIGN
CONFORMITY AND GENERAL CONFORMACE TO
CONTRACT DOCUMENTS ONLY. THE CONTRACTOR
IS RESPONSIBLE FOR CONFIRMING AND
CORRELATING DIMENSIONS AT JOBSITE FOR
TOLERANCE, CLEARANCE, QUANTITIES,
FABRICATION, COORDINATION OF HIS OR HER
WORK WITH OTHER TRADES, AND FULL

COMPLIANCE WITH CONTRACT DOCUMENTS. STATUS:

> **APPROVED** 05/07/2024

REVIEWED BY: CPD ENGINEER, EVERSTEAD ENGINEERING & DESIGN LLC.

Roof Truss Layout Scale: 3/16" = 1'