

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

Permit #:PRPWRW20242042, Public Works Right of Way Permit  
Address: 140 NW MACKENZIE DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Site Visit Inspection</b>	Bob Burns	Passed	Wednesday, May 08, 2024

**Corrective Action Required**

1 Misc

An infiltration trench was installed in the back yard and connected to a City Storm inlet via a 6" pipe. A waiver was recorded with Jackson county. The pipe was sealed properly to the inlet.

**Comments:**