

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232421
Address: 2311 SW SERENA PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|-------------------------|
| Occupancy Inspection - Codes Residential | Mitchell Schwarz | Failed | Wednesday, May 08, 2024 |

Corrective Action Required:

| | | |
|---|------|--|
| 1 | Misc | -address pending sidewalk inspection -windows in great room area to be tempered where less than 18" above floor -will re check smokes at re inspection |
|---|------|--|

Comments: