

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20224998

Address: 520 NE TOWN CENTRE DR, Unit:U, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Engineering</b>	Nick Scott	Temporary C of O	Wednesday, May 08, 2024

Informational:

1 Misc

5-8-24 NS Site visited for a TCO and the only things that need to be put on the punch list is vegetation, remove mud from parking lots and rock piles. The Detention basin is not draining with 48 hours and will need to be fixed.

**Comments:**