

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20220902
Address: 520 NE TOWN CENTRE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Punch List Inspection	Nick Scott	Partial	Wednesday, May 08, 2024

Informational:
1 Misc 12-12-23 NS Site visited and it appears that sidewalk ramps are complete.
5-8-24 NS Site visited for a TCO and the only things that need to be put on the punch list is vegetation, remove mud from parking lots and rock piles. The Detention basin is not draining with 48 hours and will need to be fixed.

Comments: