

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20224997  
Address: 520 NE TOWN CENTRE DR, Unit:T, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Khanh Nguyen	Failed	Wednesday, May 08, 2024

Corrective Action Required:

1	Misc	-Footing not approved. Inspection was not scheduled for completion of the footing -Ground the panel disconnect to ufer located at the other end. Just connect the ufer rebar to the building steel -Provide compliance with NEC 225.30. Clearly label panels and circuits supplying each building
---	------	---

**Comments:**