

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20224995
Address: 520 NE TOWN CENTRE DR, Unit:S, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Failed	Wednesday, May 08, 2024

Corrective Action Required:

1	Misc	-Footing not approved. Inspection was not scheduled for completion of the footing -Provide compliance with NEC 225.30. Clearly label panels and circuits supplying each building
---	------	---

Comments: