

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20233582
Address: 3640 SW ARBORIDGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Mitchell Schwarz	Failed	Friday, May 03, 2024

Informational:	
1 Misc	INSECTED TRENCH AND CONDUIT SOUTH OF BUILDING-Alex
Corrective Action Required:	
2 Misc	All conduit underground to be minimum 18" and 24" under parking lot/drivable surfaces

Comments: